



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29 WOBR	SLEW NOT WORKING ... DI CARD PROBLEM	DI CARD CHANGED AND TESTED	17:20:00	18:20:00	
2	CHP	CC-131	TRIPPED ON OLR	RESET DONE	19:35:00 20:45:00	19:37:00 20:48:00	
3	CHP	CC-54	TRIPPED ON OLR 3 TIMES	RESET DONE	20:15:00	20:40:00	
4	CHP	CC-36 SCR-1	BW NOT RUNNING	CHECKING GOING ON	21:45:00	22:00:00	
5	WT	AF-3	NOT RUNNING PHYSICALLY BUT SHOWING GREEN IN SYSTEM	POWER RECYCLED AND TESTED FOUND OK	17:00:00	17:20:00	
6	WT	CO-4 CD	TRIPPED ON OLR	RESET DONE	20:50:00	21:00:00	
7	WT	CC-2	POWER WAS IN OFF	MADE ON	19:30:00	19:40:00	
8	IOSA	IOSA	COMMUNICATION PROBLEM	IO RACK POWER RECYCLED IN LC-1	15:20:00 16:45:00	15:30:00 16:55:00	