



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 06/12/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	02:00:00 22:10:00 22:40:00	02:10:00 22:20:00 22:45:00	
2	OHP	TBS ON CO 7A	LT PCRD O/T ACTED	RELEASED	22:30:00	22:40:00	
3	OHP	BRC ON CO 30 B/C	OLR ACTED	RESET	00:30:00	00:55:00	
4	OHP	RSCO 10A	ZSS ACTING FREQUENTLY DUE TO PULLEY SHIFTING	BYPASSED IN MODULE	02:10:00	02:30:00	
5	OHP	BF 3A ZSS ACTING	PROBE ADJUSTMENT DONE	THEN OK	01:00:00	01:15:00	
6	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	02:45:00	05:50:00	7 TIMES
7	CHP	CC 54	OLR ACTED	RESET	00:50:00	05:45:00	18 TIMES
8	CHP	SCR 1 ON CC 34	RIGHT LIMIT NOT WORKING	BYPASSED	23:20:00	23:35:00	
9	CHP	SCR 2 ON CC 40	B/C OLR ACTED	RESET	02:00:00	02:10:00	
10	CHP	CC 102 NOT STARTING	O/P RELAY IN I/O RACK COIL SUPPLY CABLE DAMAGED BY RATS	NEW CABLE CONNECTED PROPERLY	03:40:00	04:20:00	
11	CHP	CO 26	F/G OLR ACTED	RESET	04:40:00	04:50:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 06/12/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC 9 BRS NOT RESE TTING	SENSOR ADJUSTMENT DONE	THEN OK	00:15:00	00:25:00	
13	WT	OT1	DRIVE 1 TRIPPED	RESET	00:20:00	00:25:00	