



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/11/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO-32	B/C not running	CJD acted.	22:55:00	23:10:00	Informed to operation
2	OHP	CO-29	Reported tripped	OLR acted.Reset done	22:55:00	23:00:00	
3	OHP	CO-78	Reported tripped	MCCB tripped.Made on	01:30:00	01:45:00	
4	OHP	BRC on CO-28	Reported CT not moving	Checked and found control problem.Rectified and tested okay	04:00:00	05:00:00	
5	OHP	WOBR on CO-26	Reported slew not taking place	Drive tripping on ov due to full speed. speed adjusted and tested okay	04:15:00	04:45:00	
6	OHP	BRC on CO-28	Reported B/W-2 and CT not stopping	B/W ZSS acting.Bypassed	05:40:00	05:50:00	B/W-2 ZSS to be checked
7	CHP	CC 114	Reported tripped	OLR acted.Reset done	23:45:00	23:50:00	
8	CHP	CC54	Reported tripped	OLR acted(3 times).Reset done	23:45:00	01:55:00	
9	CHP	CC-51A	Reported tripped	OLR acted.Reset done	03:55:00	04:00:00	
10	CHP	Cc131	Reported tripped	OLR acted.Reset done	04:50:00	04:55:00	
11	CHP	Cc-35	Reported tripped	OLR acted(3 times) due to deck sheet jamming.	23:14:00	00:30:00	Informed to operation
12	WT	OT-1	Reported not moving	Drive D1 tripped on PGEF fault.Reset done	23:40:00	23:45:00	