



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/06/2025

Incharge(s): V Balaji Naik,G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO6A	LT tripping frequently found M1 motor bearing problem	M1 motor power disconnected in terminal at panel	22:30:00	22:50:00	may further follow to normalize the system