



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/10/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR	RESET DONE	09:00:00	09:10:00	
2	OHP	RSCO-10A (BELT DRIVE)	TRIPPED ON OLR	RESET DONE	09:10:00	09:20:00	
3	OHP	CO-85	TRIPPED ON OLR	RESET DONE	12:15:00	12:30:00	
4	OHP	BRC ON CO-32	REPORTED LT NOT TAKING PLACE CHECKED AND FOUND BREAK PROBLEM	THRUSTER BREAK FREE IT AND CONNECTION REMOVED	12:00:00	12:15:00	
5	CHP	CC-54	TRIPPED ON OLR (5TIMES)	RESET DONE	09:00:00	10:00:00	
6	CHP	CC-38 SCR-6	LT NOT TAKING PLACE DRIVE TRIP	DRIVE RESET DONE	09:00:00	09:15:00	
7	CHP	CC-36 S-2	REPORTED LT NOT TAKING PLACE CHECKED AND FOUND PCRD GEAR BOX PROBLEM INFORMED TO MECHANICAL	AFTER FIXING GEAR BOX PCRD CABLE PROPER LAYING WAS DONE THAN OK	08:30:00 12:00:00	08:40:00 12:40:00	