



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 26/07/2025

Area: OHP

Equipment	Job
tbs on oc-22	pcrd layering done properly after mechanical guide issue rectification.
brc on co-28	pcrd cable found looped and hanging due to jamming on ground, wounded back into position after cleaning is done.
wbr-26,25	bucket wheel motor inspection is done
co-25 brs kept in circuit.	on operation request
brc-4 on 34 b/w2 zss	module replaced.. and tested.
co-68	pullchords checked. one switch contact issue found, bypassed that switch ; remaining pullchords to be kept in circuit.,
co-31a,33a,35a,37a	motor and panel ppm is done.
JH O-3	chute vibrator motors checking is done.
tt-1 chute vibrator	spare motor installed and tested.
vs-1a	dmpr and ct replaced after phase fault trippings
cr-2a	motor is replaced and testing done, bearing end shield danged motor shifted to ers. Illuminaitn improved at stair case area.
co-8a,db-1	io bits were arranged as per new io list