



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 17/01/2026

Area: WT

| Equipment      | Job  |
|----------------|--|
| OP 2           | All Motors megaring and control checking done 1AT,2AT,3AT timers time adjusted (12,7,6 sec)            |
| CP 4           | Top power collector set replaced and Trolley Line inspection and top bus bar alignment done @73 and 33 |
| OP 6           | Section isolaters maintenance done 3 nos ( Line completed)   |
| OP 1,5,6 and 8 | After rake maintenance done  |
| CP 1 and 4     | After rake maintenance done  |
| MIS            | LC 10B room cleaning done  |