



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 06/12/2025

Area: IOSA

Equipment	Job
OC-21A	FIELD DEVICES FEEDBACK CHECKING DONE. FEEDBACK CHECKED IN PLC AND HMI.
OC-21A	PPM DONE ON MOTOR.
OC-5A	LIGHTING CIRCUIT DEFECTS RECTIFIED AND PROVIDED LIGHT FITTINGS.
OC-36A	CONVEYOR GALLERY LIGHTING CIRCUIT DEFECTS RECTIFIED AND PROVIDED LIGHT FITTINGS
OC-13A	ONE ADDITIONAL LIGHT FITTING PROVIDED NEAR T/E OF OC-13A
OC-7B	PULL CHORD HARDWARE SIGNAL MISSING. RECTIFIED THE DEFECT AND KEPT IN CIRCUIT.
OC-27A	MOTOR PROTECTION RELAY PARAMETERS AND CONNECTIONS CHECKED
OC-9A	PPM DONE ON MOTOR AND FIELD DEVICES