



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/05/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc 3 on co 28	no drives running/bc ,ct,lt power off condition	poer made on and tested ok	15:45:00	16:00:00	
2	OHP	co 6	pc acted/not getting reset	pc bypassed at cjb for ope. request	15:15:00	15:30:00	
3	OHP	CO 29	PC acted /not getting reset	pc bypassed for operation request	16:00:00	16:10:00	
4	CHP	cc 131	tripped on olr /due to jamming 4 times	reset done	14:00:00	14:10:00	10.50 to 10.55 am....01.15 pm
5	WT	OT 1	INITIAL POSITION NOT GETTING	reverse limit adjusted in RL1	14:00:00	14:15:00	