



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/12/2025

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------------|-------------------------------|------------------------|----------------------------------|----------------------------------|----------|
| 1 | OHP | CR1 | MOTOR PROTECTION RELAY ACTED | RESET | 01:45:00 | 02:00:00 | |
| 2 | OHP | CO 111 | MPCB TRIPPED | MADE IT ON | 04:00:00 | 04:10:00 | |
| 3 | CHP | CC 27A T/T TO CC 40 | POSITION SENSOR GOT DISTURBED | PROPERLY FIXED THEN OK | 23:30:00 | 23:40:00 | |
| 4 | CHP | SCR 3 ON CC 33 | B/C OLR ACTED | RESET | 23:40:00 | 23:50:00 | |
| 5 | CHP | CC 51 | FEEDING CONV OLR ACTED | RESET | 22:50:00 | 05:10:00 | 11 TIMES |
| 6 | CHP | CC 131 | OLR ACTED | RESET | 00:20:00 04:20:00 23:00:00 | 00:25:00 04:25:00 23:05:00 | |
| 7 | CHP | CC 117 | OLR ACTED | RESET | 02:15:00 | 02:30:00 | |
| 8 | CHP | CC 54 | OLR ACTED | RESET | 03:15:00 | 03:20:00 | |
| 9 | CHP | CC 52 | FEEDING CONV MPD TRIP | RESET | 03:40:00 | 03:45:00 | |
| 10 | WT | AF6 | DRIVE TRIPPED | RESET | 22:25:00 | 22:30:00 | |
| 11 | WT | OT4 | DRIVE2 TRIPPED ON PGF2 | RESET | 23:20:00 | 23:30:00 | |