



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/12/2025

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment          | Problem                                 | Action             | From                             | To                               | Remarks |
|-------|------|--------------------|---|--------------------|----------------------------------|----------------------------------|---------|
| 1     | OHP  | CO 85              | OLR ACTED DUE TO HEAVY LOAD ON MATERIAL | RESET              | 00:35:00<br>01:20:00<br>04:55:00 | 00:45:00<br>01:30:00<br>05:05:00 |         |
| 2     | CHP  | CC 58              | OLR ACTED                               | RESET              | 23:05:00                         | 23:20:00                         |         |
| 3     | CHP  | CC 117             | OLR ACTED                               | RESET              | 23:50:00                         | 00:05:00                         |         |
| 4     | CHP  | CC 51              | FEEDING CONV OLR ACTED                  | RESET              | 04:00:00                         | 04:20:00                         | 3 TIMES |
| 5     | CHP  | CC 52              | FEEDING CONVEYOR MPD ACTED              | RESET              | 23:55:00                         | 00:00:00                         |         |
| 6     | CHP  | CC 131             | OLR ACTED                               | RESET              | 04:45:00                         | 04:50:00                         |         |
| 7     | CHP  | CC 54              | OLR ACTED                               | RESET              | 23:55:00                         | 04:10:00                         | 4 TIMES |
| 8     | CHP  | VF3                | DRIVE TRIP                              | RESET              | 03:25:00                         | 03:30:00                         |         |
| 9     | CHP  | SCR 9 ON<br>CC 104 | SLEW COOLING FAN TRIPPED                | MADE IT ON THEN OK | 02:30:00                         | 02:40:00                         |         |
| 10    | CHP  | SCR 1 ON<br>CC 34  | LUFF LIMIT ACTED                        | RELEASED           | 02:55:00                         | 03:10:00                         |         |