



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 18/11/2025

Area: OHP

Equipment	Job
co-34a,36a,38a,38b	motor and panel side ppm is done.
spare motors for co-14a,co-16a	shifted from jh-14 to lc-7 .
locp-1	bunker levels sensors ppm is done.
locp-1 stair case area	illumination is improved.
rbf-1a,2a,3a ; rsc-2a	motor and panel side ppm is done
ground hopper area, cf-1 t/e side	illumination is improved.
vf-1,2,3,4 and vf-8,9,10	panel and motor side inspection is done; vf-8 feed rate is increased from 70% to 90% on operation requirement.
brc-3 on co-34	b/w-2 mccb incoming and outgoing jumpers are replaced and trail run is taken.
brc-5 on co-32	fuses replaced at io rack and xmd panel at hydraulic jb and trail run is taken.
hvmcc-1 to lc4	profibus cable is laid and communication is restored.