



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 09/10/2025

Area: IOSA

Equipment	Job
OC-23A	230V POWER SOCKETS INSPECTION AND CHECKING DONE. DEFECTS NOTED AND WILL BE RECTIFIED TOMORROW.
WOBR- FLS	TESTED THRUSTER BRAKE IS FIXED IN LT M-8 . AFTER WORKING FOR FEW LT OPERATIONS STARTED TRIPPING. PRESENTLY POWER TO THRUSTER BRAKE ISOLATED AND MADE LT OPERATION HEALTHY.
WOBR-LnT	SLEW WORKING TO SLEW LUBRICATION CIRCUIT MODIFIED AND RUNNING CHECKED.
TBS	CHUTE VIBRATOR NOT WORKING, POWER CONTACTOR NOT PICKING UP. NEUTRAL WIRE WAS LOOSE IN CJB.
OC-36A	BRS UNIT AND FEEDBACK CHECKED AFTER BYPASS REMOVAL.
OC-25A	HEAD END ELECTRICAL HOIST DEFECT RECTIFIED.
OC-7B	PP DONE ON FIELD DEVICES OF ZONE-1 and 2