



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 09/12/2025

Area: CHP

Equipment	Job
SCR 6 LT	LT VFD ABB drive replaced with SIEMENS drive and tested
CC 54 Gallary	New lighting cable laid and 5nos 50W LED fixtures provided