



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/05/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO34	DRIVES ARE NOT RUNNING ACB TRIP	ACB MADE ON	19:00:00	19:20:00	
2	OHP	CO21	ZS TILTED	KEPT IN ORIGINAL POSITION	18:45:00	19:00:00	