



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/12/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WF-5	Reported ZSS acting	Probe adjustment done and tested okay	16:40:00	16:55:00	
2	OHP	CO-29	Reported tripped	OLR acted.Reset done	20:10:00	20:20:00	
3	CHP	CC-51	Reported tripped	MPD acted.Reset done(4 times)	17:30:00	19:30:00	
4	CHP	Cc-54	Reported tripped	OLR acted.Reset done(12 times)	14:00:00	21:00:00	
5	CHP	CC-55	Reported tripped	Checked and found P/C high not coming at RL-5.Bypassed at I/O rack	15:30:00	16:30:00	MPD contact to be checked