



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 01/10/2025

Area: WT

Equipment	Job
EOT Crane (O)	Main hoist UP cantactor 2C1 replaced (,110A,240V ,BCH)
MIS	OT 1,2,3 and 4 hopper area light fittings cleaning done
OP 5	After rake maintenance done, bottom C clamp adjusted
OP 4	After rake maintenance done,2 nos lugs replaced in D6