



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 26/06/2025

Area: WT

Equipment	Job
OC 1A	checked and pull card kept in circuit
OP 10	all drives checked individual found D2,D3 and D5 coupling problem informed to Mechanical
OP 10	D4 motor ,terminal block(studs) removed ,6 nos lugs replaced for winding leads and direct termination done
OP 2,4,CP 2 and 4	after rake maintenance done