



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 26/06/2025

Area: WT

| Equipment | Job |
|-------------------|--|
| OC 1A | checked and pull card kept in circuit |
| OP 10 | all drives checked individual found D2,D3 and D5 coupling problem informed to Mechanical |
| OP 10 | D4 motor ,terminal block(studs) removed ,6 nos lugs replaced for winding leads and direct termination done |
| OP 2,4,CP 2 and 4 | after rake maintenance done |