



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/01/2026

Area: WT

Equipment	Job
CP 3 jobs	I/C cable ,panel to Mast(95 *3 ) made ready
CP 3 jobs	power cable termination done @ panel side for drives
CC 4 level	Lighting complaint, rectified,3 nos L E D bulbs replaced
OP 1,4,5,6 and 8	After rake maintenance done