



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 17/11/2025

Area: IOSA

Equipment	Job
LIGHTING	LIGHTING TRANSFORMER AT OJH-12A OUTGOING TO SLDB CHECKED AND PROBLEM RECTIFIED.
BLENDER RECLAIMER	HT TRANSFORMER BASE FIXING BOLTS GOT RUSTED AND SHEARED. REPLACED AND TIGHTENED.
OC-29A	LIGHTING DEFECTS RECTIFIED AND SUFFICIENT LIGHTING ARRANGED.
OTT-1A	PPM DONE ON MOTOR AND FIELD DEVICES.