



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/12/2025

Incharge(s): Amit Roy

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|-----------------------------------|--|----------|----------|-----------------------|
| 1 | OHP | CO-25 | Reported tripped | OLR acted.Reset done | 06:50:00 | 07:00:00 | |
| 2 | OHP | BRC on CO-8A | Reported B/W-1 ZSS acting | Jamming found in both B/W-1,2 chute | 06:45:00 | 07:00:00 | Informed to operation |
| 3 | OHP | BRC on CO-8A | Reported B/W-2 not rotating | Stone stuck up | 08:50:00 | 09:10:00 | Informed to operation |
| 4 | OHP | WOBR on CO-29 | Reported slewing not taking place | Drive tripped.Reset done | 10:50:00 | 11:10:00 | |
| 5 | OHP | CO-29 | Reported tripped | OLR acted.Reset done | 11:20:00 | 11:30:00 | |
| 6 | CHP | CC 31 SCR-4 | LT not taking place | Wrong complaint | 06:55:00 | 07:10:00 | |
| 7 | CHP | CC 125 | Reported tripped | OLR acted.Reset done | 08:14:00 | 08:19:00 | |
| 8 | CHP | CC 34 SCR-1 | Slew not taking place | Control MCB tripped.Made on | 11:43:00 | 11:55:00 | |
| 9 | CHP | CC 40 SCR-2 | Slew not taking place | Drive tripped.Reset done | 12:00:00 | 12:10:00 | |
| 10 | CHP | Cc-51 | MPD tripped | Feeding conveyor stopped.Reset done(8 times) | 08:00:00 | 12:00:00 | |
| 11 | CHP | Cc-53 | Reported tripped | MPCB tripped.Made on | 09:00:00 | 09:15:00 | |
| 12 | CHP | Cc-22(B/D) | Reported tripped | OLR acted.Reset done | 10:00:00 | 10:10:00 | |