



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 08/07/2025

Area: IOSA

Equipment	Job
1-14LBDS2 PLC	PROFIBUS PLC 90-30 REMOVED.
5.5KW	MOTOR MEGGERED AND NO-LOAD TRIAL RUN TAKEN , CURRENTS RECORDED.
OC-31A AND OC-33A	LIGHTING DEFECTS RECTIFIED AND PROVIDED SUFFICIENT LIGHTING.
MISC	HOUSEKEEPING DONE IN 1-142LC3 AND STEPS OF 1-142LC2.
OC-5A	PPM DONE ON MOTOR.
OC-6A	PPM DONE ON FIELD DEVICES .
WOBR ( L and T)	LIGHTING DEFECTS AT SLEW PLATFORM, BOOM CONVEYOR AND OPERATOR CABIN AREA RECTIFIED AND PROVIDED SUFFICIENT LIGHTING.
WOBR (L and T)	WOBR TO OCR-2 COMMUNICATION IS MISSING SOME TIMES. CLEANED ALL CONNECTORS TO ETHERNET SWITCH ,PLC AND RADIO MODEM.
OC-19A	DE-WATERING PUMPS CHECKING DONE ON AUTO.