



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 25/10/2025

Area: WT

Equipment	Job
AF 4(O)	Removed motor shifted to tippler house and checked winding values found ok
AF 4(O)	Motor tested with spare drive found Ok
OP 4	After rake maintenance done