



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/07/2025

Area: WT

| Equipment | Job |
|-----------|--|
| OP 9 | Modification for drive bypass and drive in circuit option provided in SCADA |
| CT 1 | Hooper area one no 200W LED replaced and 2 nos Tubes replaced in coal scooter shed |
| OT 5 | New 'SICK' Anti collision device installed at out haul side wagon sensor for testing purpose |
| OP 2 | panel and motor side ppm done ,D5 OLR replaced and kept in circuit |
| OP4 and 6 | after rake maintenance done |