



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/07/2025

Shift: A

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO11 carriage drive	MPCB trip	Reset done	11:00:00	11:10:00	
2	OHP	CO35	Over load trip 2 times	Reset done	10:05:00	10:10:00	11.00am to 11.05am
3	OHP	WOBR on CO26	Slew not working found drive trip	Reset done then ok	11:20:00	11:30:00	
4	OHP	BRC on CO34	BW rotating slow	Not an electrical problem informed to mechanical	11:00:00	11:12:00	may check concern dept further in G shift
5	CHP	Shifting of S2 from repair bay to CC36	TUL CJS not working found module problem	New module replaced then ok	07:00:00	08:00:00	
6	CHP	SCR4 on CC33	BW and slew not working found slew hose damaged and oil leakage	Informed to mechanical slew hose replaced then ok	08:20:00	08:30:00	
7	CHP	CC203	Not running found OLR acted inMPD	reset done	09:00:00	09:10:00	
8	CHP	SCR3 on CC38	Luffing down limit bypassed as per operational request	Again palced in CKT as per operational equest	09:40:00	09:50:00	
9	CHP	CC111	Pull card acted found IO rake side cable loose	wires tightened then ok	09:45:00	10:00:00	
10	CHP	CC51	Over load acted	Reset done	13:25:00	13:30:00	
11	CHP	CC54	Over load acted	Reset done	10:23:00	10:25:00	10.33am to 10.35am



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/07/2025

Shift: A

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC113	CJS acted due to jamming	After clearing jam reset done then ok	11:30:00	11:32:00	Jamm cleared from 11.30am to 12.00am
13	CHP	CC 17	olr acted	reset	11:30:00	11:35:00	
14	CHP	SCR2 on CC34	LT not working found PCRD cable over tension limit acted	OT limit released then ok	13:20:00	13:30:00	