



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 10/12/2025

Area: WT

| Equipment | Job |
|------------------|--|
| AF 5 and 6 Level | Lighting, circuit problem rectified and 2 nos 200W LEDs replaced |
| OP 3 and 6 | After rake, maintenance done |