



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 03/12/2025

Area: OHP

Equipment	Job
eot-1 hoist	ppm is done. illumination is improved .
co-10a,rco-6a,rsc-1a,vf-1a,2a,bf-3a,4a,5a,vs-1a to vs-5a, bf-1a,2a,7a,8a,9a	4a,5a and panel ppm is done,
co-60 overmaterial sensor	cable laid from sensor jb to co-60 cjb ;
om-15	mcc door and control chamber job welded back in position and closed properly
rco-1a gallery ; co-59 side gallery	lighting is improved
mmf cable retrival from hvmcc-1 is done	retried at hvmcc-1
tis-2 on co-6 power cable issue	unused feeder cable to ground hopper level checking is done
wbr-4 on co-6a ; brc-5 on co-32 ; co-32,6a,31. co-15	ppm is done.