



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/08/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO21	BRS bypassed as per operational requirement	bypassed	01:10:00	01:20:00	
2	OHP	TIS 5 on CO25	Bypassed as per operational request	bypaased	02:00:00	02:20:00	
3	OHP	VF8a	Chute vibrator MPCB trip	Reset and made on	23:40:00	23:45:00	
4	CHP	CC-34 SCR-2	LUFF OIL TEMPERATURE	KEPT IN CKT	22:30:00	22:40:00	
5	CHP	SCR-10 ON CC-105	BC MPD TRIPPED ON EF	RESET DONE AND TESTED	03:30:00	03:45:00	
6	CHP	CC-40	BRS UNIT NO POWER.... FUSE blown	REPLACED AND TESTED	02:50:00	03:10:00	
7	CHP	CC-37 S-1	SIGNAL MISSING FREQUENTLY	SCR-2 USED AS repeater FOR S-1	22:30:00	22:50:00	
8	CHP	CC-113	STOPPED ON ZSS	PULLY SLIPPING	05:15:00	05:25:00	
9	CHP	CC28	chute sensor malfunctioning due to rain	Bypassed	04:45:00	04:44:00	may check further
10	WT	OP-2	BOTTOM PAD C AND U CLAMP PROBLEM	CHANGED	22:00:00	23:00:00	
11	WT	CO3 belt	olr acted	reset done	04:45:00	04:50:00	