



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 21/11/2025

Area: WT

| Equipment | Job |
|---------------|---|
| CP 1 | After rake maintenance done |
| OP2,4,6 and 7 | After rake maintenance done |
| OP 6 | 5A2, rotor cantactor coil found burnt, replaced it |
| OP 6 | D5 and D6 checked in de clutch found cascade time not rotating (to be rectified) |
| MIs | 13 nos C clamps assembled for pusher |
| MIS | vacum cantactor (3TF68) repaired and tested ,kept as spare |
| MIS | spare Brake Panel shifted and kept as spare in LC 9 |