



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/09/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-63	MPCB TRIPPED	RESET DONE	02:30:00 02:45:00	02:40:00 02:54:00	
2	OHP	CO-61	TRIPPED ON OLR	RESET DONE	00:20:00	00:35:00	
3	OHP	CO-19 TBS	LT NOT WORKING DUE TO LT IN LOCAL MODE	KEPT IN REMOTE	23:45:00	00:00:00	
4	OHP	CO-67	TRIPPED ON OLR	RESET DONE	22:55:00	23:05:00	
5	CHP	CC-15	TRIPPED ON OLR	RESET DONE	03:40:00	03:50:00	
6	CHP	CC-37 SCR-7	SIGNAL MISSING	LT DONE THEN OK	00:00:00 01:00:00	00:20:00 01:30:00	
7	CHP	CC-32 SCR-5	BC TRIPPED ON OLR	RESET DONE	00:00:00	00:20:00	
8	CHP	CC-112 SCR-8	BC NOT STARTED	FAULT RESET DONE	00:00:00	00:25:00	
9	CHP	CC-112 SCR-8	BC TRIPPED ON OLR	RESET DONE	02:45:00	03:00:00	
10	CHP	CC-42	TRIPPED ON OLR	RESET DONE	03:45:00	03:50:00	
11	CHP	CC-40 SCR-3	SLEW NOT WORKING	LIMIT ACTED DUE TO COAL JAMMING ... RELEASED	05:15:00	05:30:00	
12	CHP	CC-54	TRIPPED ON OLR ( FOUR TIMES )	RESET DONE	23:05:00	02:10:00	
13	CHP	CC-131	TRIPPED ON OLR	RESET DONE	01:50:00 04:50:00	01:55:00 04:55:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/09/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-51	MPD TRIPPED (9 TIMES FEEDING CONVEYOR STOPPED)	RESET DONE	03:05:00	05:05:00	
15	WT	OC-1A	FAIL TO START DUE TO PULL CORD ACTED	RELEASED	23:00:00	23:30:00	