



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/10/2025

Area: WT

Equipment	Job
LC 1 and 9	water levels inspection done ,de watering is going on
OT Bay area	Lighting job done,350W 1 no,200W 4nos LEDs and 1no 400W SV lamp replaced
OT 2 series	Motor side ppm done
OP 6	Panel and Motor side ppm done
OP 2,4 and 5	After rake maintenance done