



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 15/07/2025

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	TRIPPED ON OLR	RESET DONE	07:44:00 08:50:00	07:49:00 09:00:00	
2	OHP	CO-26 WBR	NO DRIVES WORKING	END LIMIT ACTED ... BYPASSED AND LT DONE .. THEN AGAIN KEPT IN CKT	10:00:00	10:18:00	
3	OHP	CO-6A WBR	OIL TEMP HIGH	OIL COOLER BYPASSED AND RUN FOR 30 MINTS THEN NORMALIZED AFTER TEMP COMING DOWN	11:30:00	12:00:00	
4	OHP	BRC ON CO -32	LT NOT WORKING	SKEW LIMIT ACTED ... INFORMED MECH FOR ADJUSTMENT	12:30:00	12:45:00	
5	OHP	CO-25 WBR	YARD TO BC INTER LOCK CAGE STUCK	MADE FREE	12:55:00	13:10:00	
6	OHP	TT-2	LT NOT MOVING	CABLE CUT ... MATERIAL JAMMING .. AFTER CLEANING JOINT DONE AND GIVEN CLEARANCE	11:15:00	13:15:00	
7	OHP	CO-15	BRS BYPASS REQ BECOUSE OF BELT PIECES	BYPASSED	09:15:00	09:20:00	
8	OHP	CO-3B	PULL CORD PROBLEM FROM C SHIFT	BYPASSED	07:15:00	07:30:00	
9	OHP	ALL YARD MACHINE	NO POWER	LBDS -5 IC-2 NO POWER ... RESTORED AFTER DNW CLEARANCE	13:40:00	14:00:00	
10	CHP	CC-17	TRIPPED ON OLR	RESET DONE	10:30:00	10:40:00	
11	CHP	CC-104 SCR-9	SLEW NOT WORKING	SPIDER TRIPPING IN CHARGE PRESSURE .. RESET DONE AND INFORMED HYDRAULIC GROUP	09:30:00	09:50:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/07/2025

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-39 S-1	NO POWER	HT CABLE CAME OUT OF COUPLER .. CHECKED WITH G SHIFT .. MEGGERING DONE FOUND OK ..	10:30:00	11:30:00	INFORMED DNW