



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/08/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on co 34	charge pressure 1 acted	reset	13:33:00	13:45:00	
2	OHP	TIS 6	not healthy,bypassed loop loose connection in l/o Rack	loop tightened	11:10:00	11:25:00	
3	OHP	BRC on CO 8A	b/c not stopped after yard conveyor stopped,module malfunctioning	module replaced	11:45:00	12:10:00	
4	CHP	CC 37 S1	LT not working,end limit acted	bypassed and refer to G Shift	06:45:00	07:00:00	
5	CHP	CC 105 SCR10	b/c not running,olr acted	reset	07:45:00	08:10:00	
6	CHP	CC 37 S1	luff not working,airlock	informed mech	08:00:00	08:15:00	
7	CHP	CC 38 SCR 6	slew not working,jamming	informed operation	08:20:00	08:30:00	
8	CHP	CC 201	OLr acted	reset	08:20:00	08:35:00	
9	CHP	CC 31 SCR 4	luff not working,up limit acted	released and informed operation	09:01:00	09:25:00	
10	CHP	CC 105 SCR 10	LT not working,m2 mpcb trips	reset	13:00:00	13:15:00	
11	CHP	CC 40 SCR 3	B/c not running,zss cage stucked	made free	12:15:00	12:25:00	
12	CHP	CC 105 SCR 10	LT not stopping,local permissive relay from PLC got stucked	local permissive relay coil connection removed	13:35:00	13:55:00	refer to G shift
13	WT	CO 3(b)	OLR acted	reset	13:25:00	13:29:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/08/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OP2	no power ACB tripped,c clamp u clamp damaged @ col no 36	bottom C clamp ,U clamp replaced	09:35:00	11:45:00	