



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/08/2025

Shift: A

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	REPORTED RED OLR ACTED	OLR RESET	06:40:00	06:50:00	
2	OHP	RSCO-10A(C/D)	NOT TAKING PLACE OLR ACTED	RESET	07:00:00	07:15:00	
3	OHP	CO-33M	REPORTED RED OLR ACTED	RESET	11:20:00	11:30:00	
4	CHP	CC-54	REPORTED RED OLR ACTED	RESET	09:40:00	09:50:00	
5	CHP	CC-58	STOPPING ON ZS FREQUANTLY CHECKED PROBE DAMAGED	ZS PROBE REPLACED THAN OK	09:30:00	10:00:00	
6	CHP	CC-114	OLR ACTED	RESET	10:30:00	10:40:00	
7	CHP	CC-28(B/D)	OLR ACTED	RESET	08:35:00	08:40:00	
8	CHP	CC-111 S-3	SLEW NOT TAKING PLACE NO PROBLEM	WRONG COMPLAINT	06:30:00	06:50:00	
9	CHP	CC-35 SCR-1	B/W NOT RUNNING OLR ACTED	RESET	08:20:00	08:30:00	
10	CHP	CC-111 S-3	LT NOT TAKING PLACE M-3 OLR ACTED	RESET	08:10:00	08:30:00	DUE TO TRACK JAMMING
11	CHP	CC-111 S-3	SIGNAL MISSING	LT TAKEN FWD THAN OK	08:10:00	08:30:00	
12	CHP	CC 35 SCR-1	Luffing not taking place	Oil level low.	09:20:00	09:45:00	informed to mechanical
13	CHP	CC 34 SCR-2	LT not taking place	PCRD overtension acted. Released and tested okay	12:10:00	12:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/08/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OP-8	Reported Forward movement not taking place	Checked and found OT-4 limits earth fault. Control MCB tripping in I/O rack. Temporary Bypassed and clearance given	07:30:00	08:00:00	LS4 new cable laid from OT-4 JB to limit switch and limits kept in line at 11.20AM