



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/11/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 29	olr acted	reset	02:40:00	02:50:00	
2	OHP	CO 35	olr acted	reset	03:00:00	03:05:00	
3	CHP	CC 36	BRS not reset,sensor alignment problem	sensor adjusted	22:40:00	23:00:00	
4	CHP	CC 107	motor olr acted	reset	02:00:00	02:10:00	
5	CHP	CC 112 scr8	b/c not running,	fault reset done	02:20:00	02:35:00	
6	CHP	cc 125	olr acted	reset	03:30:00	03:40:00	
7	CHP	CC 34 scr2	LT not working,motor tripped	reset,track jamming,informed operation	04:25:00	04:35:00	
8	CHP	CC 28	OLr acted	reset	22:20:00	22:30:00	
9	CHP	CC 110	zss acted,gear box problem	informed mechanical	03:20:00	03:30:00	
10	IOSA	TBS	healthy signal not coming to OCR2,modem Ethernet adapter in lower house no power ,cjd fuse blown in PLC panel,plc mcb tripped	separate 230 given to switch board of Ethernet adapter(EOP),PLC mcb made on,cjd fuse replaced	02:50:00	03:50:00	