



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/07/2025

Area: WT

Equipment	Job
OT 4 Modification	Separate Break mode is provided and programming done accordingly (selector is provided at CD)
OP 8	VFD drive shifted ,installed in D2. termination and testing done ,OK kept in circuit (6nos in circuit)
OP 9	All drives de clutched and each drive clutched and checked all 6 no drives found OK
OP 9	D5 (M2), direction checked,control fuse replaced for Revers ,kept in circuit
OP 4 ,6 and CP 2	after rake maintenance done
OC 1A Level	Lighting problem rectified,3 nos 35W and 1no tube LEDs replaced