



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 06/10/2025

Incharge(s): MAHENDRA SOLANKI

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO30	BW NOT STARTING	OIL LEVEL LOW INFORMED MECH	09:30:00	09:45:00	
2	OHP	BRC ON CO 30	LT PCRD O/T	RESET	11:15:00	11:30:00	
3	OHP	WOBR ON CO25	B/C NOT RUNNING	CONTROL MCB REST	12:35:00	13:00:00	
4	OHP	TBS ON 7A	PCRD O/T AND CABLE FALL DOWN	PCRD WINDUP	11:40:00	12:10:00	
5	CHP	CC37	SCR7 SLEW PROBLEM BREAK FAIL	SPIDER RESET	06:25:00	06:40:00	
6	CHP	CC45	TRIP OVERLOAD	RESET	07:45:00	07:55:00	
7	CHP	CC34	SCR2 SLEW DRIVE TRIP	RESET	08:00:00	08:20:00	
8	CHP	CC36	SCR1 LUFF PROBLEM	RESET	10:20:00	10:35:00	
9	CHP	CC107	OVERLOAD	RESET	10:05:00	10:15:00	
10	CHP	CC201	OVERLOAD	RESET	13:45:00	13:55:00	
11	WT	EOT OT3	TRIP	RESET	10:00:00	10:15:00	
12	WT	OP10	POWER INDICATION LAMP @TROLLY LINE NOT GLOWING	CABLE GOT SHORT, CABLE AND LAMP REPLCED	11:00:00	12:30:00	
13	WT	OP5	NOT MOVING O/L	RESET	11:00:00	11:15:00	
14	IOSA	TBS LT	NOT WORKING	END LIMIT RESET	11:00:00	11:20:00	