



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/09/2025

Incharge(s): Lal Singh

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|--|---|----------------------|----------------------|---------|
| 1 | OHP | CO-63 | MPCB TRIPPED | RESET DONE | 02:30:00 02:45:00 | 02:40:00 02:54:00 | |
| 2 | OHP | CO-61 | TRIPPED ON OLR | RESET DONE | 00:20:00 | 00:35:00 | |
| 3 | OHP | CO-19 TBS | LT NOT WORKING DUE TO LT IN LOCAL MODE | KEPT IN REMOTE | 23:45:00 | 00:00:00 | |
| 4 | OHP | CO-67 | TRIPPED ON OLR | RESET DONE | 22:55:00 | 23:05:00 | |
| 5 | CHP | CC-15 | TRIPPED ON OLR | RESET DONE | 03:40:00 | 03:50:00 | |
| 6 | CHP | CC-37 SCR-7 | SIGNAL MISSING | LT DONE THEN OK | 00:00:00 01:00:00 | 00:20:00 01:30:00 | |
| 7 | CHP | CC-32 SCR-5 | BC TRIPPED ON OLR | RESET DONE | 00:00:00 | 00:20:00 | |
| 8 | CHP | CC-112 SCR-8 | BC NOT STARTED | FAULT RESET DONE | 00:00:00 | 00:25:00 | |
| 9 | CHP | CC-112 SCR-8 | BC TRIPPED ON OLR | RESET DONE | 02:45:00 | 03:00:00 | |
| 10 | CHP | CC-42 | TRIPPED ON OLR | RESET DONE | 03:45:00 | 03:50:00 | |
| 11 | CHP | CC-40 SCR-3 | SLEW NOT WORKING | LIMIT ACTED DUE TO COAL JAMMING ... RELEASED | 05:15:00 | 05:30:00 | |
| 12 | CHP | CC-54 | TRIPPED ON OLR (FOUR TIMES) | RESET DONE | 23:05:00 | 02:10:00 | |
| 13 | CHP | CC-131 | TRIPPED ON OLR | RESET DONE | 01:50:00 04:50:00 | 01:55:00 04:55:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/09/2025

Incharge(s): Lal Singh

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|--|------------|----------|----------|---------|
| 14 | CHP | CC-51 | MPD TRIPPED (9 TIMES FEEDING CONVEYOR STOPPED) | RESET DONE | 03:05:00 | 05:05:00 | |
| 15 | WT | OC-1A | FAIL TO START DUE TO PULL CORD ACTED | RELEASED | 23:00:00 | 23:30:00 | |