



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/05/2025

Shift: B

Incharge(s): Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-33M BRC	PUMP NOT STARTING ... OIL LEVEL LOW	INFORMED FOR OIL FILLING ... AFTER YTHAT ALSO OIL LEVEL NOT HEALTHY ... SENSOR PROBLEM INFORME INSTRUMENTATION	15:30:00	17:50:00	
2	OHP	CO-32 BRC	CT NOT WORKING	WAS IN LOCAL ... KEPT IN REMOTE	18:45:00	19:00:00	
3	OHP	CO-35	TRIPPED ON OLR	RESET DONE	20:25:00	20:30:00	
4	OHP	CO-3B	BRS BYPASS REQ	BYPASSED IN MODULE	21:10:00	21:20:00	BELT HOLE
5	OHP	CO-32 BRC	BC NOT WORKING	OLR TRIPPED DUE TO STONE STUCK.. RESET DONE	21:00:00	21:15:00	
6	OHP	CO-29 WOBR	LUFF DOWN L/S BYPASS REQUEST	BYPASSED	18:00:00	18:10:00	
7	CHP	cc-44	TRIPPED ON OLR	RESET DONE	14:10:00 19:00:00	14:20:00 19:10:00	
8	CHP	CC-40 SCR-6	SLEW NOT WORKING	MATERIAL JAMMING ... INFORMED FOR CLEANING	17:15:00	17:30:00	
9	CHP	SCR-5 ON CC-32	BC NOT WORKING	OLR TRIPPED ... RESET DONE	18:00:00	18:15:00	
10	CHP	S-1 CC-31	PCRD CHAIN AND GUIDE PROBLEM	PCRD DRUM ARRESTED AFTER TAKING TO TAIL END ...	18:55:00	19:50:00	
11	CHP	CC-35 SCR-2	SLEW 30 DEGREE LIMIT MALFUNCTIONING ... BYPASSED	BC STOPPED DUE TO CHUT JAMMING .. INFORMED FOR CLEANING	17:50:00	18:30:00	
12	CHP	CC 131	TRIPPED IN OLR	RESET DONE	15:50:00 19:00:00	15:55:00 19:05:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/05/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-51A	TRIPPED IN OLR	RESET DONE	19:10:00	19:15:00	
14	CHP	CC-52	DRIVE SELECTION MISSING	LOOSE CONNECTION TIGHTENING DONE	14:30:00	14:35:00	
15	WT	OP-5	D2 TRIPPED ON OVERLOAD	RESET DONE	19:35:00	19:45:00	
16	IOSA	OC-7A	TRIPPING ON UV	CHECKIN GOING ON	21:47:00	22:00:00	TO BE CHECKED FURTHER