



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/11/2025

Area: WT

Equipment	Job
OT 4	LS 1, replaced with new and tested, bypass removed
OT 4	Initial indication, target (BOLT) position changed and adjusted probe accordingly
OP 6	Motor side ppm done
OP 2, 3, 4, 5 and 8	After rake, maintenance done