



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/02/2026

Area: OHP

| Equipment | Job |
|-----------------|--|
| wobr-4 on co-6a | ppm is done. |
| co-11a | pullchord and bss switch were replaced and restored in circuit. gallery lighting is improved. |
| lbds-4 io rack | space power source cable from lbds-4 to 1-14lbds1 is traced, will be used as alternate supply for RIO at 1-1lbds4. |
| co-26 | motor changing job is under progress. |