



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/01/2026

Shift: A

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-6A	ZSS acting	Probe cable got cut.Rejoint done and tested okay	07:30:00	07:45:00	
2	OHP	WOBR on CO-26	Slewing towards CHP side not taking place	Limit handle removed and tested okay	07:00:00	07:20:00	
3	OHP	BRC on CO-33M	LT not taking place	PCRD tension acted.Released and tested okay	08:45:00	09:00:00	
4	OHP	BRC on CO-28	CT not taking place	Drive tripped.Reset done	10:05:00	10:15:00	
5	OHP	CO-85	Reported tripped	OLR acted.Reset done	10:15:00	10:25:00	
6	OHP	CO-33M	Reported tripped	OLR acted.Reset done	13:40:00	13:50:00	
7	CHP	CC-37 SCR-7	Luff up not taking place	Limit acted.Released and tested okay	06:35:00	06:45:00	
8	CHP	CC-32 SCR-5	LT not taking place	Drive tripped.Reset done	06:50:00	07:05:00	
9	CHP	Cc-40 SCR-2	Slewing not taking place	Wrong complaint	09:25:00	09:35:00	
10	CHP	Cc-107	Reported tripped	OLR acted.Reset done	10:12:00	10:20:00	
11	CHP	CC-112 SCR-8	Slewing not taking place	Limit acted.Released and tested okay	11:05:00	11:20:00	
12	CHP	Cc-108	Reported tripped	OLR acted.Reset done	11:40:00	11:50:00	
13	WT	OP-5	Reported tripped	D-2 tripped.Reset done	13:05:00	13:15:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/01/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OP-1 to OP-6	Communication problem	PLC recycled and tested okay	08:55:00	09:00:00	