



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/04/2025

Area: CHP

Equipment	Job
JH C3	Hoist and LDB panels maintenance was done
CC 13,17,24	PPM was done
CC 51	4nos BS switches installed
Stacker 2	Slew DC motors and panel removed ,new panel and DBR UNITS installed.