



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 06/12/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO-30	Reported B/C not running.	CJD acted due to scrapper problem.CJD reset done	17:00:00	17:10:00	Informed to mechanical
2	OHP	BRC on CO-30	Reported B/C not running	OLR acted.Reset done	16:50:00	17:00:00	
3	OHP	CO-13(C/D)	Reported tripped	OLR acted.Reset done	17:15:00	17:25:00	
4	OHP	WOBR on CO-29	Reported B/C not running	OLR acted.Reset done	19:30:00	19:40:00	
5	OHP	TBS on CO-7A	Reported LT not taking place	Reclaiming limit tied with rope and tested okay	21:30:00	21:40:00	
6	CHP	CC-110	Reported ZSS acting	Material jamming.	17:05:00	17:25:00	Informed to operation
7	CHP	CC-111,CC 104,CC105, CC112	M/C no power	OM breaker in off condition in LC-2.Breaker made on and Panels charged and 230V Dc restored and machine ACB's made on and tested okay	15:30:00	16:10:00	
8	CHP	Cc-51	Reported tripped	MPD tripped.Reset done(5 times)	19:55:00	20:45:00	
9	CHP	Cc 105 scr-10	Reported no drives working	PLC power card failed.Replaced and tested okay	18:30:00	20:15:00	
10	CHP	CC-104 SCR-9	Reported no drives working	ACB tripped.Made on and found PLC fault EB03 fault.Power recycled done at operator cabin and MCC panel and plc kept in stop mode and put in run mode and found communication to be okay.	18:30:00	20:20:00	
11	WT	CC-3(C/D)	Reported tripped	OLR acted.Reset done(@times)	14:15:00 15:00:00	14:25:00 15:10:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 06/12/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	WT	CO-3(B/D)	Reported tripped	OLR acted.Reset done	20:25:00	20:30:00	