



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/06/2025

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO33M	DRIVE CHANGED	CHECKED AND GOVEN CLEARENCE	06:00:00	09:00:00	
2	OHP	Brc on co 30 lt	pcrd o/t acted	released	08:10:00	08:30:00	
3	OHP	CO 84 PC ACTING REPORTED	EMERGENCY IS ACTED	RELEASED	11:30:00	11:40:00	
4	OHP	CO 29	OLR ACTED	RESET	08:40:00	08:50:00	
5	CHP	CC 125	OLR ACTED	RESET	11:00:00 13:45:00	11:10:00 13:50:00	
6	CHP	SCR 10 ON CC 105	NEW CAGE FIXED FOR RECLAIMING YARD INTERLOCK	CHECKED AND GIVEN CLEARENCE	10:30:00	11:00:00	
7	CHP	CC 131	OLR ACTED	RESET	08:20:00	08:30:00	
8	CHP	CC 58	OLR ACTED	RESET	13:20:00	13:40:00	
9	CHP	RG1 ACTING DUE TO UNDER SPEED	MODULE PROBLEM	BYPASSED	10:30:00	11:00:00	
10	CHP	CC 51	B/S ACTED	RESET	07:15:00	07:30:00	
11	IOSA	OLD WBR NO DRIVE RUNNING	AUXILIARY SUPPLY IS IN OFF CONDITION	MADE IT ON	07:20:00	07:30:00	