



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 27/04/2025

Area: CHP

Equipment	Job
JH C3	Hoist and LDB panels maintenance was done
CC 13,17,24	PPM was done
CC 51	4nos BS switches installed
Stacker 2	Slew DC motors and panel removed ,new panel and DBR UNITS installed.