



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 14/06/2025

Area: CHP

Equipment	Job
RG,JH 7	Chute vibrators inspected and ckt problems rectified. RG 2 chute vibrator base welded
LC 14	One 30w lamp replaced
CC 220/221	Lighting ckt problem rectified
CC 43/44	5nos 35w LED fixtures replaced and improved lighting
CC 111	Reclaimer inter lock cage provided
CC 111,S 3,13,19,22	PPM was done
SCR 1	Slew motor replaced ,aligned and trial run was taken