



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/05/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co 33m	bw s are not running/oil level low	inform to operation and mech.	16:15:00	16:30:00	
2	OHP	co 34	tripped on thermal olr .	reset done	20:00:00	20:15:00	
3	CHP	R1 on cc31	luffing not working/oil level low inform to mech. and ope.	.	19:30:00	19:45:00	
4	CHP	R1 on cc31	bc not running/olr tripped in mpd	reset done	20:00:00	20:10:00	
5	CHP	cc131	tripped on olr/due to jamming	reset done	20:40:00	20:45:00	
6	CHP	cc 130	zss acted/didnt found any problem	power and control recycled then ok.	19:30:00	19:45:00	
7	WT	co 3 b/d	tripped on olr due to jamming	reset done	18:30:00	18:40:00	