



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/07/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	TRIPPED ON OLR	RESET DONE	03:45:00	03:50:00	
2	OHP	CO-20 TBS	LT NOT WORKING BECAUSE OF PCRD OVER TENSION	RELEASED	03:50:00	04:00:00	
3	CHP	CC-51	TRIPPED ON OLR	RESET DONE	01:40:00	01:45:00	
4	CHP	CC-36 S-1	SIGNAL MISSING	PLC AND MODEM POWER RECYCLE	00:30:00	00:50:00	
5	CHP	CC-40 SCR-6	SLEW NOT WORKING	PUMP STOPPING IN BETWEEN ... AIR BLAST COOLER MPCB AUX CONTACT MISSING ... bypassed	01:00:00	01:50:00	TO BE CHANGED
6	CHP	CC-33	TRIPPED ON OLR	RESET DONE	02:35:00 03:00:00 03:30:00 05:00:00	02:45:00 03:15:00 03:45:00 05:15:00	
7	CHP	CC-32 SCR -5	YARD LATE STOPPING AFTER BC STOP ... AS PER OPERATION	INTERLOCK CHECKED FOUND OK	03:30:00	03:45:00	
8	CHP	CC-54	TRIPPED ON OLR	RESET DONE	04:30:00 05:10:00	04:35:00 05:15:00	